

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPJN/AGR/05/25/285

Dated: 26-05-2025

It is certified that an inspection team headed by Mr. Mahesh Kumar/AE (Name of Officers
with designation) from U.P. Jal Nigam (Rural), Agra, inspected the K.S.I. College, Patholi,
Agra (Name & Address of the school) on 15-05-2025 (date of inspection) and on the

basis of Water Test Report (Attached) ✓
bearing no UPJN/AGR/05/25/285 dated 26-05-2025 of

Regional Level Water Analysis Laboratory (UP JAL NIGAM) certified that the
K.S.I. College (Name of school) has safe drinking water facilities for the students and
members of staff of the institution. School also maintains the hygienic sanitation condition in
the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 6 months from issue date

Signature with Seal: [Signature]

Name: Sir Mahesh Kumar

Designation: AE

Name & Address of the Office / Department: [Blank]

To
PRINCIPAL
K.S.I. College,
Patholi. Agra





Regional Water Testing Laboratory

Address: 4/4 Sanjay Palace U.P. JalNigam(Rural) Agra, 282002



TEST REPORT

Report No:	UPJN/AGR/05/25/285	Issue Date:	26/05/2025	Page No	2
------------	--------------------	-------------	------------	---------	---

Customer Details

Office Name and Address	PRINCIPAL K S I COLLEGE SADAR, SIKARI ROAD ,PATHOLI ,AGRA
Ref Letter No & Date	

Basic details of sample

District	Agra	Block	-
Gram Panchayat	----	Village/city	PATHOLI
Water Source	Supply water	Location	SADAR, SIKARI ROAD ,PATHOLI
Quantity of Sample	1 Lt.	Sample No.	01
Receiving Date	14/05/2025	Date of Collection	08/05/2025
Sample Depositor	-	S. Collector	-
		Sampling Method	As per IS 17614: Part 1: 2021
Analysis Start Date	15/05/2025	Analysis Completion Date:	18/05/2025

Technical Data of Analysis

S.No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500:2012		Ref. Method of Analysis Joint testing(100-130)
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25°C)	7.17	6-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity mg/L	1.42	1	5	IS 3025 (Pt 10):1984 (Nephelometric Method)
3	Total Dissolved Solid mg/L	152	500	2000	IS 3025 (Pt 16):1984 (Gravimetric Method)
4	Fluoride mg/L	.628	1	1.5	APHA 23 rd Edition 4500-F Method C (Electrode method) 2017
5	Total Hardness mg/L	28	200	600	IS 3025 (Part 21):2009(EDTA Method)
6	Total Alkalinity mg/L	56	200	600	IS 3025 (Part 23):1986 (Potentiometric method)
7	Chloride mg/L	38	250	1000	IS 3025 (Part 32):1988 (Argentometric method)
8	Iron mg/L	-	1	1	APHA 23 rd Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate mg/L	02	200	400	APHA 23 rd Edition 4500-SO4 Method E (Turbidity Method) 2017
10	Calcium mg/L	18	75	200	IS 3025 (Part 40):1991(EDTA Titrimetric Method)
11	Magnesium mg/L	2.43	30	100	IS 3025 (Part 46):1994(Volumetric Method)
12	Color (Hazen)	02	5	15	APHA 23 rd Edition Color 2120 B (Visual Comparison Method)
13	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (PART 08) 1984 (Qualitative Method)



Regional Water Testing Laboratory

Address: 4/4 Sanjay Palace U.P. JalNigam(Rural) Agra, 282002



TC-9960

14	Nitrate (mg/l)	02	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)
----	----------------	----	----	----	--

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Reviewed By


(Amita Devi)

(Deputy Quality Manager)


(Sanjay Upman)

Authorized Signatory:

Testing Lab In charge

Laboratory Contact details
Email- ZlaupjnR@gmail.com
Mob. (8630905287)

Mob-9761093634

-----End of Report-----